



中国认可
国际互认
检测
TESTING
CNAS L4062



TEST REPORT

Reference No. : WTF22X09190623W003
Manufacturer : Mid Ocean Brands B.V.
Address : 7/F., Kings Tower, 111 King Lam Street, Cheung Sha Wan, Kowloon, Hong Kong
Factory : 117237
Product Name : Table Light wireless charger
Model No. : MO6346
Standards : ETSI EN 301 489-1 V2.2.3 (2019-11)
ETSI EN 301 489-3 V2.1.1 (2019-03)
Date of Receipt sample : 2022-9-30
Date of Test : 2022-9-30 to 2022-12-06
Date of Issue : 2022-12-06
Test Report Form No. : WTX_ETSI EN 301 489_1_2019W
Test Result : Pass

Remarks:

The results shown in this test report refer only to the sample(s) tested, this test report cannot be reproduced, except in full, without prior written permission of the company. The report would be invalid without specific stamp of test institute and the signatures of approver.

Prepared By:

Waltek Testing Group (Shenzhen) Co., Ltd.

Address: 1/F., Room 101, Building 1, Hongwei Industrial Park, Liuxian 2nd Road,
Block 70 Bao'an District, Shenzhen, Guangdong, China

Tel.: +86-755-33663308 Fax.: +86-755-33663309 Email: sem@waltek.com.cn

Tested by:

Dashan Chen

Dashan Chen

Approved by:

Silin Chen

Silin Chen



TABLE OF CONTENTS

1. GENERAL INFORMATION.....	5
1.1 PRODUCT DESCRIPTION FOR EQUIPMENT UNDER TEST (EUT).....	5
1.2 TEST STANDARDS.....	6
1.3 TEST METHODOLOGY.....	6
1.4 TEST FACILITY.....	6
1.5 EUT SETUP AND OPERATION MODE.....	7
1.6 PERFORMANCE CRITERIA FOR EMS.....	8
1.7 MEASUREMENT UNCERTAINTY.....	9
1.8 TEST EQUIPMENT LIST AND DETAILS.....	10
2. SUMMARY OF TEST RESULTS.....	13
3. CONDUCTED EMISSIONS.....	14
3.1 TEST PROCEDURE.....	14
3.2 BASIC TEST SETUP BLOCK DIAGRAM.....	14
3.3 ENVIRONMENTAL CONDITIONS.....	14
3.4 CONDUCTED EMISSIONS TEST DATA.....	14
4. RADIATED EMISSIONS.....	19
4.2 TEST PROCEDURE.....	19
4.2 CORRECTED AMPLITUDE & MARGIN CALCULATION.....	19
4.3 ENVIRONMENTAL CONDITIONS.....	20
4.4 SUMMARY OF TEST RESULTS/PLOTS.....	20
5. HARMONIC CURRENT EMISSIONS.....	24
5.1 TEST PROCEDURE.....	24
5.2 TEST SETUP BLOCK DIAGRAM.....	24
5.3 TEST STANDARDS.....	24
5.4 ENVIRONMENTAL CONDITIONS.....	24
5.5 HARMONIC CURRENT EMISSIONS TEST DATA.....	24
6. VOLTAGE FLUCTUATION AND FLICKER.....	30
6.1 TEST PROCEDURE.....	30
6.2 TEST SETUP BLOCK DIAGRAM.....	30
6.3 TEST STANDARDS.....	30
6.4 ENVIRONMENTAL CONDITIONS.....	30
6.5 VOLTAGE FLUCTUATION AND FLICKER TEST DATA.....	30
7. ELECTROSTATIC DISCHARGE (ESD).....	32
7.1 TEST PROCEDURE.....	32
7.2 TEST SETUP BLOCK DIAGRAM.....	32
7.3 TEST PERFORMANCE.....	32
7.4 ENVIRONMENTAL CONDITIONS.....	32
7.5 ELECTROSTATIC DISCHARGE IMMUNITY TEST DATA.....	32
8. RADIO FREQUENCY ELECTROMAGNETIC FIELD (R/S).....	34
8.1 TEST PROCEDURE.....	34
8.2 TEST SETUP BLOCK DIAGRAM.....	34
8.3 TEST PERFORMANCE.....	34
8.4 ENVIRONMENTAL CONDITIONS.....	34
8.5 CONTINUOUS RADIATED DISTURBANCES TEST DATA.....	34
9. FAST TRANSIENTS, COMMON MODE (EFT).....	36
9.1 TEST PROCEDURE.....	36
9.2 TEST SETUP BLOCK DIAGRAM.....	36
9.3 TEST PERFORMANCE.....	36
9.4 ENVIRONMENTAL CONDITIONS.....	36
9.5 ELECTRICAL FAST TRANSIENTS TEST DATA.....	36



10. SURGES	38
10.1 TEST PROCEDURE.....	38
10.2 TEST SETUP BLOCK DIAGRAM	38
10.3 TEST PERFORMANCE	38
10.4 ENVIRONMENTAL CONDITIONS	38
10.5 SURGE TEST DATA	38
11. RADIO FREQUENCY, COMMON MODE (C/S)	40
11.1 TEST PROCEDURE.....	40
11.2 TEST SETUP BLOCK DIAGRAM	40
11.3 TEST PERFORMANCE	40
11.4 ENVIRONMENTAL CONDITIONS	40
11.5 CONTINUOUS CONDUCTED DISTURBANCES TEST DATA	40
12. VOLTAGE DIPS AND INTERRUPTIONS.....	42
12.1 TEST PROCEDURE.....	42
12.2 TEST SETUP BLOCK DIAGRAM	42
12.3 TEST PERFORMANCE	42
12.4 ENVIRONMENTAL CONDITIONS	42
12.5 VOLTAGE DIPS AND INTERRUPTIONS TEST DATA	42
EXHIBIT 1 - EUT PHOTOGRAPHS.....	43
EXHIBIT 2 - TEST SETUP PHOTOGRAPHS	44

WALTEK



Report version

Version No.	Date of issue	Description
Rev.00	2022-12-06	Original
/	/	/

WALTEK



1. GENERAL INFORMATION

1.1 Product Description for Equipment Under Test (EUT)

General Description of EUT	
Product Name:	Table Light wireless charger
Trade Name:	/
Model No.:	MO6346
Adding Model(s):	/
Rate Power:	Input: 5V/2A, 9V/2A Wireless Output: 10W Max
Software Version:	V1.2
Hardware Version:	NY-01-4IN1-V1.1
Note: The test data is gathered from a production sample, provided by the manufacturer.	

Technical Characteristics of EUT	
EN 303417	
Frequency Range:	110-205kHz
Radiated H-Field:	34.43dBuA/m(@3m)
Type of Antenna:	Coil Antenna
Note: The Antenna Gain is provided by the customer and can affect the validity of results.	



1.2 Test Standards

The tests were performed according to following standards:

ETSI EN 301 489-1 V2.2.3 (2019-11): Electromagnetic Compatibility (EMC) standard for radio equipment and services; Part 1: Common technical requirements; Harmonised Standard for Electromagnetic Compatibility.

ETSI EN 301 489-3 V2.1.1 (2019-03): Electromagnetic Compatibility (EMC) standard for radio equipment and services; Part 3: Specific conditions for Short-Range Devices (SRD) operating on frequencies between 9 kHz and 246 GHz; Harmonised Standard covering the essential requirements of article 3.1(b) of Directive 2014/53/EU.

Maintenance of compliance is the responsibility of the manufacturer. Any modification of the product maybe which result in lowering the emission/immunity should be checked to ensure compliance has been maintained.

1.3 Test Methodology

All measurements contained in this report were conducted with the standard ETSI EN 301489-1, Electromagnetic compatibility and Radio spectrum Matters (ERM); Electromagnetic Compatibility (EMC) standard for radio equipment and services; Part 1: Common technical requirements.

1.4 Test Facility

Address of the test laboratory

Laboratory: Waltek Testing Group (Shenzhen) Co., Ltd.

Address: 1/F., Room 101, Building 1, Hongwei Industrial Park, Liuxian 2nd Road, Block 70 Bao'an District, Shenzhen, Guangdong, China

FCC – Registration No.: 125990

Waltek Testing Group (Shenzhen) Co., Ltd. EMC Laboratory has been registered and fully described in a report filed with the FCC (Federal Communications Commission). The acceptance letter from the FCC is maintained in our files. The Designation Number is CN5010, and Test Firm Registration Number is 125990.

Industry Canada (IC) Registration No.: 11464A

The 3m Semi-anechoic chamber of Waltek Testing Group (Shenzhen) Co., Ltd. has been registered by Certification and Engineering Bureau of Industry Canada for radio equipment testing with Registration No.: 11464A.



1.5 EUT Setup and Operation Mode

The equipment under test (EUT) was configured to measure its highest possible emission/immunity level. The test modes were adapted according to the operation manual for use, more detailed description as follows:

Test Mode List		
Test Mode	Description	Remark
TM1	Wireless Charging& USB full load	Connect to the adapter; AC230V/50Hz for adapter; Wireless charging: output 5W& USB full load 5W
TM2	Wireless Charging& USB full load	Connect to the adapter; AC230V/50Hz for adapter; Wireless charging: output 10W& USB full load 10W
TM3	Wireless Charging	TT,CT for EMS testing

EUT Cable List and Details			
Cable Description	Length (m)	Shielded/Unshielded	With / Without Ferrite
USB Cable	1.0	Unshielded	Without Ferrite

Special Cable List and Details			
Cable Description	Length (m)	Shielded/Unshielded	With / Without Ferrite
/	/	/	/

Auxiliary Equipment List and Details			
Description	Manufacturer	Model	Serial Number
wireless charging tester	YBZ	YBZ wireless charging tester	/
Adapter	Xiaomi	MDY-08-ES	/



1.6 Performance Criteria for EMS

➤ EN 301 489-3, The performance criteria are:

In the table below:

- performance criterion A applies for immunity tests with phenomena of a continuous nature;
- performance criterion B applies for immunity tests with phenomena of a transient nature.

NOTE: Whether a phenomenon is considered transient, continuous or otherwise is indicated in the test procedures for the phenomenon in ETSI EN 301 489-1 [1], clause 9.

Table 2: Performance Requirements

Criterion	During test	After test
A	Operate as intended No loss of function No unintentional responses	Operate as intended No loss of function No degradation of performance No loss of stored data or user programmable functions
B	May show loss of function No unintentional responses	Operate as intended Lost function(s) shall be self-recoverable No degradation of performance No loss of stored data or user programmable functions

Where "operate as intended" or "no loss of function" is specified, the EUT shall demonstrate correct functioning as described in ETSI EN 301 489-3 [1], clause 5.

Where the EUT has more than one mode of operation (see clause 4.5.2), an unplanned transition from one mode to another is considered as an unintentional response. The EUT shall be tested in sufficient modes to confirm there are no such unintentional responses.



1.7 Measurement Uncertainty

Measurement uncertainty	
Parameter	Uncertainty
Uncertainty for Radiated Emission in 3m chamber	@30-200MHz $\pm 4.52\text{dB}$ @0.2-1GHz $\pm 5.56\text{dB}$ @1-6GHz $\pm 3.84\text{dB}$ @6-18GHz $\pm 3.92\text{dB}$
Uncertainty for Conducted Emission	@9-150kHz $\pm 3.74\text{dB}$ @0.15-30MHz $\pm 3.34\text{dB}$
Uncertainty for Harmonic test	3.26%
Uncertainty for Flicker test	4.76%
Uncertainty for RS test	21%, k=2
Uncertainty for CS test	29%, k=2
Uncertainty for ESD test	The immunity measurement system uncertainty is within standard requirement and is based on a standard uncertainty multiplied by a coverage factor k=2, providing a level of confidence of approximately 95%.
Uncertainty for EFT test	
Uncertainty for Surges test	
Uncertainty for Voltage Dips, Voltage Variations and Short Interruptions Test	
Uncertainty for PFMF test	



1.8 Test Equipment List and Details

Description	Manufacturer	Model	Serial Number	Cal Date	Due Date
☒ Chamber A: Below 1GHz					
Spectrum Analyzer	Rohde & Schwarz	FSP30	836079/035	2022-03-22	2023-03-21
EMI Test Receiver	Rohde & Schwarz	ESVB	825471/005	2022-03-22	2023-03-21
Amplifier	Agilent	8447F	3113A06717	2022-01-07	2023-01-06
Loop Antenna	Schwarz beck	FMZB 1516	9773	2021-03-20	2023-03-19
Trilog Broadband Antenna	Schwarz beck	VULB9163	9163-333	2021-03-20	2023-03-19
☐ Chamber A: Above 1GHz					
Spectrum Analyzer	Rohde & Schwarz	FSP30	836079/035	2022-03-22	2023-03-21
Spectrum Analyzer	Rohde & Schwarz	FSP40	100612	2022-03-22	2023-03-21
EMI Test Receiver	Rohde & Schwarz	ESVB	825471/005	2022-03-22	2023-03-21
Amplifier	C&D	PAP-1G18	2002	2022-03-22	2023-03-21
Horn Antenna	ETS	3117	00086197	2021-03-19	2023-03-18
Horn Antenna	Schwarzbeck	BBHA 9170	BBHA9170582	2021-04-27	2023-04-26
Pre-amplifier	Schwarz beck	BBV 9721	9721-031	2022-03-25	2023-03-24
☐ Chamber B:Below 1GHz					
Trilog Broadband Antenna	Schwarz beck	VULB9163(B)	9163-635	2021-04-09	2023-04-08
Amplifier	Agilent	8447D	2944A10179	2022-03-22	2023-03-21
EMI Test Receiver	Rohde & Schwarz	ESPI	101391	2022-03-25	2023-03-24
☐ Chamber C:Below 1GHz					
EMI Test Receiver	Rohde & Schwarz	ESIB 26	100401	2022-01-07	2023-01-06
Trilog Broadband Antenna	Schwarz beck	VULB 9168	1194	2021-05-28	2023-05-27
Amplifier	HP	8447F	2944A03869	2022-03-22	2023-03-21
☒ Conducted Room 1#					
EMI Test Receiver	Rohde & Schwarz	ESPI	101611	2022-03-22	2023-03-21
Pulse Limiter	Rohde & Schwarz	ESH3-Z2	100911	2022-03-25	2023-03-24
AC LISN	Schwarz beck	NSLK8126	8126-224	2022-03-22	2023-03-21
8-WIRE LISN	Schwarz beck	8158	CAT3-8158-0059	2022-03-22	2023-03-21
8-WIRE LISN	Schwarz beck	8158	CAT5-8158-0117	2022-03-22	2023-03-21
☐ Conducted Room 2#					
EMI Test Receiver	Rohde & Schwarz	ESPI	10129	2022-03-22	2023-03-21
LISN	Rohde & Schwarz	ENV 216	100097	2022-03-22	2023-03-21
EMF					
VDH Test Head	AFJ	VDH 30	SC022Z	2022-03-25	2023-03-24
3 Loop Antenna					
Loop Antenna	ZHINAN	ZN30401	19037	2021-04-26	2023-04-25



Clamp					
Clamp	Luthi	MDS21	3809	2022-03-28	2023-03-27
PFMF					
PMF Generator	LIONCEL	PMF-801C-C	0171101	2022-03-22	2023-03-21
PMF Antenna	LIONCEL	PMF-801C-A	0180302	2022-03-22	2023-03-21
Instantaneous PMF Generator Module	LIONCEL	PMF-801C-T	0171001	2022-03-22	2023-03-21
H/F					
Digital Power Analyzer	California Instrument	CTS	72831	2022-03-22	2023-03-21
Power Source	California Instrument	5001IX-CTS-400	25965	2022-03-22	2023-03-21
ESD					
ESD Generator	LIONCEL	ESD-203B	0170901	2022-03-28	2023-03-27
EFT/SURGE/DIPS					
Transient 2000	EMC PARTNER	TRA2000	863	2022-03-22	2023-03-21
Couple Clamp	EMC PARTNER	CN-EFT1000	513	2022-03-22	2023-03-21
CS					
CONDUCTED IMMUNITY TEST SYSTEM	FRANKONIA	CIT-10/75	126B1247/2013	2022-01-07	2023-01-06
Attenuator	EMTEST	MA-5100/6BF2	1009	2022-03-22	2023-03-21
CDN	Luthi	L-801M2/M3	2665	2022-03-22	2023-03-21
CDN	LIONCEL	CDN-T8	0210401	2022-03-25	2023-03-24
EM Clamp	TESEQ	KEMZ801A	45028	2022-03-25	2023-03-24
RS					
Signal Generator	HP	8688B	3438A00604	2022-03-22	2023-03-21
Power Meter	KEITHLEY	3500	1162591	2022-03-22	2023-03-21
Power Meter	KEITHLEY	3500	1121428	2022-03-22	2023-03-21
RF Power Amplifier	MicoTop	MPA-80-1000-25 0	MPA1906239	2022-03-22	2023-03-21
RF Power Amplifier	MicoTop	MPA-80-6000-10 0	MPA1906238	2022-03-22	2023-03-21
Antenna	SCHWARZBECK	STLP 9129	9129 114	N/A	N/A
Power Meter	Agilent	E4419B	GB42420578	2022-03-22	2023-03-21



Software List			
Description	Manufacturer	Model	Version
EMI Test Software (Radiated Emission)*	Farad	EZ-EMC	RA-03A1
EMI Test Software (Conducted Emission)*	Farad	EZ-EMC	RA-03A1

*Remark: indicates software version used in the compliance certification testing.

WALTEK



2. SUMMARY OF TEST RESULTS

Standards	Reference	Description of Test Item	Result
ETSI EN 301 489-1	8.2	Radiated Emissions	Pass
	8.3	Conducted Emissions for DC Power Port	N/A
	8.4	Conducted Emissions for AC Power Port	Pass
	8.5	Harmonic Current Emissions	Pass
	8.6	Voltage Fluctuations and Flicker	Pass
	8.7	Telecommunication Ports	N/A
	9.2	Radio Frequency Electromagnetic Field	Pass
	9.3	Electrostatic Discharge	Pass
	9.4	Fast Transients, Common Mode	Pass
	9.5	Radio Frequency, Common Mode	Pass
	9.6	Transient and Surges in the Vehicular Environment	N/A
	9.7	Voltage Dips and Interruptions	Pass
	9.8	Surges	Pass
Pass: The EUT complies with the essential requirements in the standard. Fail: The EUT does not comply with the essential requirements in the standard. N/A: Not applicable.			




3. Conducted Emissions

3.1 Test Procedure

Test is conducting under the description of EN55032 Information technology equipment - Radio disturbance characteristics - Limits and methods of measurement.

3.2 Basic Test Setup Block Diagram



3.3 Environmental Conditions


Temperature:	23.5 ° C
Relative Humidity:	54 %
ATM Pressure:	1015 mbar

3.4 Conducted Emissions Test Data

Note: Only show the worst case in the test report.




Test mode:	TM1	Polarity:	Neutral
------------	-----	-----------	---------



No.	Frequency (MHz)	Reading (dBuV)	Correct (dB)	Result (dBuV)	Limit (dBuV)	Margin (dB)	Detector
1	1.0780	24.99	10.15	35.14	56.00	-20.86	QP
2	1.1420	16.87	10.15	27.02	46.00	-18.98	AVG
3	2.3460	27.55	10.26	37.81	56.00	-18.19	QP
4	2.3460	21.31	10.26	31.57	46.00	-14.43	AVG
5	2.7900	28.50	10.27	38.77	56.00	-17.23	QP
6	3.0460	23.95	10.28	34.23	46.00	-11.77	AVG
7	4.4420	33.61	10.31	43.92	56.00	-12.08	QP
8	4.6940	28.66	10.32	38.98	46.00	-7.02	AVG
9	7.7380	37.47	10.34	47.81	60.00	-12.19	QP
10*	7.9940	32.67	10.34	43.01	50.00	-6.99	AVG
11	13.6380	29.93	10.27	40.20	50.00	-9.80	AVG
12	15.0380	34.44	10.24	44.68	60.00	-15.32	QP




Test mode:	TM1	Polarity:	Line
------------	-----	-----------	------



No.	Frequency (MHz)	Reading (dBuV)	Correct (dB)	Result (dBuV)	Limit (dBuV)	Margin (dB)	Detector
1	0.3900	25.32	10.23	35.55	58.06	-22.51	QP
2	0.3900	19.22	10.23	29.45	48.06	-18.61	AVG
3	1.0780	24.15	10.15	34.30	56.00	-21.70	QP
4	1.0780	16.94	10.15	27.09	46.00	-18.91	AVG
5	2.0299	27.14	10.25	37.39	56.00	-18.61	QP
6	2.2860	21.32	10.26	31.58	46.00	-14.42	AVG
7	3.2339	30.30	10.28	40.58	56.00	-15.42	QP
8	3.4900	26.40	10.29	36.69	46.00	-9.31	AVG
9	4.9500	33.63	10.33	43.96	56.00	-12.04	QP
10	5.1379	29.44	10.33	39.77	50.00	-10.23	AVG
11	7.9299	37.90	10.34	48.24	60.00	-11.76	QP
12*	8.4380	32.88	10.34	43.22	50.00	-6.78	AVG




Test mode:	TM2	Polarity:	Neutral
------------	-----	-----------	---------



No.	Frequency (MHz)	Reading (dBuV)	Correct (dB)	Result (dBuV)	Limit (dBuV)	Margin (dB)	Detector
1	1.7780	26.65	10.23	36.88	56.00	-19.12	QP
2	1.8380	19.43	10.23	29.66	46.00	-16.34	AVG
3	2.5380	30.08	10.26	40.34	56.00	-15.66	QP
4	2.5380	22.83	10.26	33.09	46.00	-12.91	AVG
5	3.2340	31.35	10.28	41.63	56.00	-14.37	QP
6	3.2340	25.11	10.28	35.39	46.00	-10.61	AVG
7	4.8860	34.62	10.33	44.95	56.00	-11.05	QP
8	5.3300	29.58	10.33	39.91	50.00	-10.09	AVG
9	7.4860	37.95	10.34	48.29	60.00	-11.71	QP
10*	7.9940	32.47	10.34	42.81	50.00	-7.19	AVG
11	13.6420	35.33	10.27	45.60	60.00	-14.40	QP
12	14.3380	29.88	10.25	40.13	50.00	-9.87	AVG



Test mode:	TM2	Polarity:	Line
------------	-----	-----------	------




No.	Frequency (MHz)	Reading (dBuV)	Correct (dB)	Result (dBuV)	Limit (dBuV)	Margin (dB)	Detector
1	0.3700	24.35	10.23	34.58	58.50	-23.92	QP
2	0.3740	17.61	10.23	27.84	48.41	-20.57	AVG
3	0.5620	14.55	10.21	24.76	46.00	-21.24	AVG
4	0.5660	24.54	10.21	34.75	56.00	-21.25	QP
5	0.8900	24.20	10.16	34.36	56.00	-21.64	QP
6	0.8900	15.89	10.16	26.05	46.00	-19.95	AVG
7	2.5380	29.42	10.26	39.68	56.00	-16.32	QP
8	2.5380	23.71	10.26	33.97	46.00	-12.03	AVG
9	7.2340	37.45	10.34	47.79	60.00	-12.21	QP
10*	7.2980	32.78	10.34	43.12	50.00	-6.88	AVG
11	13.8940	35.26	10.26	45.52	60.00	-14.48	QP
12	14.0860	30.40	10.26	40.66	50.00	-9.34	AVG



4. Radiated Emissions

4.2 Test Procedure

Test is conducting under the description of EN55032 Information technology equipment - Radio disturbance characteristics - Limits and methods of measurement.



4.2 Corrected Amplitude & Margin Calculation

The Corrected Amplitude is calculated by adding the Antenna Factor and the Cable Factor, and subtracting the Amplifier Gain from the Amplitude reading. The basic equation is as follows:

$$\text{Corr. Ampl.} = \text{Indicated Reading} + \text{Antenna Factor} + \text{Cable Factor} - \text{Amplifier Gain}$$

The "**Margin**" column of the following data tables indicates the degree of compliance with the applicable limit. For example, a margin of -6dB μ V means the emission is 6dB μ V below the maximum limit for Class B device. The equation for margin calculation is as follows:

$$\text{Margin} = \text{Corr. Ampl.} - \text{EN 301489 Class B Limit}$$



4.3 Environmental Conditions


Temperature:	22.5° C
Relative Humidity:	54%
ATM Pressure:	1011 mbar

4.4 Summary of Test Results/Plots

Note: Only show the worst case in the test report

➤ 30MHz to 1GHz


Test mode:	TM1	Polarity:	Horizontal
------------	-----	-----------	------------



No.	Frequency (MHz)	Reading (dBuV/m)	Correct dB/m	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Degree ()	Height (cm)	Remark
1	52.0251	30.75	-7.67	23.08	40.00	-16.92	-	-	QP
2	98.8326	28.10	-8.38	19.72	40.00	-20.28	-	-	QP
3	176.2686	33.48	-10.33	23.15	40.00	-16.85	-	-	QP
4	304.6100	31.95	-4.94	27.01	47.00	-19.99	-	-	QP
5	562.6624	28.47	-0.86	27.61	47.00	-19.39	-	-	QP
6	679.9600	28.90	1.05	29.95	47.00	-17.05	-	-	QP




Test mode:	TM1	Polarity:	Vertical
------------	-----	-----------	----------



No.	Frequency (MHz)	Reading (dBuV/m)	Correct dB/m	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Degree ()	Height (cm)	Remark
1	43.9658	39.24	-7.19	32.05	40.00	-7.95	-	-	QP
2	47.9940	42.70	-7.27	35.43	40.00	-4.57	-	-	QP
3	52.0251	42.15	-7.67	34.48	40.00	-5.52	-	-	QP
4	63.9828	40.82	-9.87	30.95	40.00	-9.05	-	-	QP
5	128.1130	44.65	-10.27	34.38	40.00	-5.62	-	-	QP
6	143.8295	48.89	-11.49	37.40	40.00	-2.60	-	-	QP




Test mode:	TM2	Polarity:	Horizontal
------------	-----	-----------	------------



No.	Frequency (MHz)	Reading (dBuV/m)	Correct dB/m	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Degree ()	Height (cm)	Remark
1	55.0274	31.70	-8.19	23.51	40.00	-16.49	-	-	QP
2	64.4331	27.72	-9.95	17.77	40.00	-22.23	-	-	QP
3	112.5244	29.59	-8.31	21.28	40.00	-18.72	-	-	QP
4	144.3348	33.30	-11.51	21.79	40.00	-18.21	-	-	QP
5	263.8190	31.87	-6.24	25.63	47.00	-21.37	-	-	QP
6	308.9126	31.74	-4.87	26.87	47.00	-20.13	-	-	QP



Test mode:	TM2	Polarity:	Vertical
------------	-----	-----------	----------



No.	Frequency (MHz)	Reading (dBuV/m)	Correct dB/m	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Degree ()	Height (cm)	Remark
1	39.9942	40.09	-7.11	32.98	40.00	-7.02	-	-	QP
2	47.9940	41.59	-7.27	34.32	40.00	-5.68	-	-	QP
3	63.9828	42.94	-9.87	33.07	40.00	-6.93	-	-	QP
4	72.0843	43.57	-11.25	32.32	40.00	-7.68	-	-	QP
5	80.0806	43.38	-11.92	31.46	40.00	-8.54	-	-	QP
6	147.9214	48.21	-11.61	36.60	40.00	-3.40	-	-	QP

Remark: '-' Means the test Degree and Height are not recorded by the test software and only show the worst case in the test report.




5. Harmonic Current Emissions

5.1 Test Procedure

Test is conducting under the description of EN 61000-3-2.

5.2 Test Setup Block Diagram



5.3 Test Standards

EN61000-3-2, Clause 7.1 Limits for Class A equipment.

5.4 Environmental Conditions

Temperature:	25°C
Relative Humidity:	50%
ATM Pressure:	1011 mbar

5.5 Harmonic Current Emissions Test Data



Harmonics – Class-A

Test category: Class-A (European limits)

Test Margin: 100

Test date: 2022/10/8

Start time: 16:21:25

End time: 16:24:06


Test duration (min): 2.5

Data file name: H-000411.cts_data

Comment: TM2


Test Result: Pass

Source qualification: Normal

Current & voltage waveforms

Harmonics and Class A limit line

European Limits

**Test result: Pass** **Worst harmonics H15-13.9% of 150% limit, H15-20.7% of 100% limit**



Current Test Result Summary (Run time)

Test category: Class-A (European limits)

Test Margin: 100

Test date: 2022/10/8

Start time: 16:21:25

End time: 16:24:06

Test duration (min): 2.5

Data file name: H-000411.cts_data

Comment: TM2

Test Result: Pass

Source qualification: Normal

THC(A): 0.185

I-THD(%): 188.5

POHC(A): 0.042

POHC Limit(A): 0.251

Highest parameter values during test:

V_RMS (Volts): 230.17

Frequency(Hz): 50.00

I_Peak (Amps): 0.933

I_RMS (Amps): 0.213

I_Fund (Amps): 0.098

Crest Factor: 4.472

Power (Watts): 22.1

Power Factor: 0.456

Harm#	Harms(avg)	100%Limit	%of Limit	Harms(max)	150%Limit	%of Limit	Status
2	0.001	1.080	N/A	0.001	1.620	N/A	Pass
3	0.093	2.300	4.0	0.095	3.450	2.7	Pass
4	0.001	0.430	N/A	0.001	0.645	N/A	Pass
5	0.086	1.140	7.5	0.087	1.710	5.1	Pass
6	0.000	0.300	N/A	0.001	0.450	N/A	Pass
7	0.076	0.770	9.9	0.077	1.155	6.7	Pass
8	0.000	0.230	N/A	0.001	0.345	N/A	Pass
9	0.065	0.400	16.3	0.066	0.600	10.9	Pass
10	0.000	0.184	N/A	0.001	0.276	N/A	Pass
11	0.053	0.330	16.1	0.053	0.495	10.8	Pass
12	0.000	0.153	N/A	0.001	0.230	N/A	Pass
13	0.041	0.210	19.6	0.041	0.315	13.2	Pass
14	0.000	0.131	N/A	0.001	0.197	N/A	Pass
15	0.031	0.150	20.7	0.031	0.225	13.9	Pass
16	0.000	0.115	N/A	0.001	0.173	N/A	Pass
17	0.023	0.132	17.8	0.024	0.198	11.9	Pass
18	0.000	0.102	N/A	0.001	0.153	N/A	Pass
19	0.019	0.118	16.3	0.020	0.178	11.0	Pass
20	0.000	0.092	N/A	0.001	0.138	N/A	Pass
21	0.018	0.107	16.9	0.018	0.161	11.4	Pass
22	0.000	0.084	N/A	0.001	0.125	N/A	Pass
23	0.018	0.098	18.2	0.018	0.147	12.3	Pass
24	0.000	0.077	N/A	0.001	0.115	N/A	Pass
25	0.017	0.090	19.1	0.017	0.135	12.9	Pass
26	0.000	0.071	N/A	0.001	0.107	N/A	Pass



Reference No.: WTF22X09190623W003

27	0.016	0.083	18.9	0.016	0.125	12.8	Pass
28	0.000	0.066	N/A	0.001	0.099	N/A	Pass
29	0.014	0.078	17.6	0.014	0.116	11.9	Pass
30	0.000	0.061	N/A	0.001	0.092	N/A	Pass
31	0.011	0.073	15.7	0.012	0.109	10.6	Pass
32	0.000	0.058	N/A	0.001	0.086	N/A	Pass
33	0.009	0.068	13.9	0.010	0.102	9.4	Pass
34	0.000	0.054	N/A	0.001	0.081	N/A	Pass
35	0.008	0.064	12.9	0.008	0.096	8.8	Pass
36	0.000	0.051	N/A	0.001	0.077	N/A	Pass
37	0.008	0.061	13.0	0.008	0.091	8.9	Pass
38	0.000	0.048	N/A	0.001	0.073	N/A	Pass
39	0.008	0.058	13.5	0.008	0.087	9.2	Pass
40	0.000	0.046	N/A	0.001	0.069	N/A	Pass

WALTEK



Voltage Source Verification Data (Run time)

Test category: Class-A (European limits)

Test Margin: 100

Test date: 2022/10/8

Start time: 16:21:25

End time: 16:24:06

Test duration (min): 2.5

Data file name: H-000411.cts_data

Comment: TM2

Test Result: Pass

Source qualification: Normal

Highest parameter values during test:

Voltage (Vrms): 230.17

Frequency(Hz): 50.00

I_Peak (Amps): 0.933

I_RMS (Amps): 0.213

I_Fund (Amps): 0.098

Crest Factor: 4.472

Power (Watts): 22.1

Power Factor: 0.456

Harm#	Harmonics V-rms	Limit V-rms	% of Limit	Status
2	0.065	0.460	14.12	OK
3	0.514	2.071	24.82	OK
4	0.073	0.460	15.81	OK
5	0.065	0.920	7.02	OK
6	0.034	0.460	7.32	OK
7	0.042	0.690	6.01	OK
8	0.014	0.460	3.06	OK
9	0.037	0.460	8.12	OK
10	0.008	0.460	1.74	OK
11	0.042	0.230	18.42	OK
12	0.009	0.230	4.05	OK
13	0.030	0.230	12.83	OK
14	0.006	0.230	2.81	OK
15	0.035	0.230	15.22	OK
16	0.008	0.230	3.63	OK
17	0.025	0.230	10.68	OK
18	0.010	0.230	4.33	OK
19	0.019	0.230	8.32	OK
20	0.014	0.230	6.30	OK
21	0.020	0.230	8.70	OK
22	0.005	0.230	2.02	OK
23	0.020	0.230	8.81	OK
24	0.004	0.230	1.69	OK
25	0.022	0.230	9.68	OK
26	0.003	0.230	1.21	OK
27	0.018	0.230	7.99	OK



Reference No.: WTF22X09190623W003

28	0.004	0.230	1.60	OK
29	0.024	0.230	10.24	OK
30	0.003	0.230	1.35	OK
31	0.019	0.230	8.14	OK
32	0.003	0.230	1.23	OK
33	0.017	0.230	7.30	OK
34	0.002	0.230	0.89	OK
35	0.014	0.230	6.25	OK
36	0.003	0.230	1.11	OK
37	0.013	0.230	5.53	OK
38	0.003	0.230	1.19	OK
39	0.014	0.230	5.96	OK
40	0.008	0.230	3.41	OK

WALTEK




6. Voltage Fluctuation and Flicker

6.1 Test Procedure

Test is conducting under the description of EN 61000-3-3.

6.2 Test Setup Block Diagram



6.3 Test Standards

EN61000-3-3, Limit: Clause 5.

6.4 Environmental Conditions

Temperature:	25°C
Relative Humidity:	50%
ATM Pressure:	1011 mbar

6.5 Voltage Fluctuation and Flicker Test Data


Result: The EUT is compliance with the requirements of this section.




Test mode:	TM1
------------	-----

Test Result: Pass Status: Test Completed

Pst_i and limit line **European Limits**



Plt and limit line



Parameter values recorded during the test:

Vrms at the end of test (Volt): 230.08			
Highest dt (%):		Test limit (%):	
T-max (mS):	0	Test limit (mS):	500.0 Pass
Highest dc (%):	0.00	Test limit (%):	3.30 Pass
Highest dmax (%):	0.00	Test limit (%):	4.00 Pass
Highest Pst (10 min. period):	0.224	Test limit:	1.000 Pass
Highest Plt (2 hr. period):	0.098	Test limit:	0.650 Pass




7. Electrostatic Discharge (ESD)

7.1 Test Procedure

Test is conducting under the description of EN 61000-4-2.

7.2 Test Setup Block Diagram



7.3 Test Performance

Performance Criterion:	Mode	Verdict
	TM1-TM3	B
Note: TM3 for TT,TR		

7.4 Environmental Conditions

Temperature:	25°C
Relative Humidity:	50%
ATM Pressure:	1011 mbar

7.5 Electrostatic Discharge Immunity Test Data



Test mode	TM1-TM3							
EN 61000-4-2 Test Points	Test Levels (kV)							
	-2	+2	-4	+4	-6	+6	-8	+8
Air Discharge								
USB Port	B	B	B	B	B	B	B	B
Gap	B	B	B	B	B	B	B	B
Enclosure	B	B	B	B	B	B	B	B
Direct Contact Discharge								
/	/	/	/	/	/	/	/	/
Indirect Contact Discharge								
HCP (6 Sides)	A	A	A	A	/	/	/	/
VCP (4 Sides)	A	A	A	A	/	/	/	/

Test Result: Pass

WALTEK




8. Radio Frequency Electromagnetic Field (R/S)

8.1 Test Procedure

Test is conducting under the description of EN 61000-4-3.

8.2 Test Setup Block Diagram



8.3 Test Performance

Performance Criterion:	Mode	Verdict
	TM1-TM3	A
Note: TM3 for CT,CR		

8.4 Environmental Conditions

Temperature:	25°C
Relative Humidity:	50%
ATM Pressure:	1011 mbar

8.5 Continuous Radiated Disturbances Test Data

Frequency step: 1% of fundamental

Dwell time: 1 second

Modulation: AM by 1kHz sine wave with 80% modulation depth



Test mode		TM1-TM3							
Frequency Range(MHz)	Field (V/m)	Front		Rear		Left Side		Right Side	
		VERT	HORI	VERT	HORI	VERT	HORI	VERT	HORI
80-1000	3	A	A	A	A	A	A	A	A
1000-3000	3	A	A	A	A	A	A	A	A
3000-6000	3	A	A	A	A	A	A	A	A

Test Result: Pass

WALTEK




9. Fast Transients, Common Mode (EFT)

9.1 Test Procedure


Test is conducting under the description of EN 61000-4-4.

9.2 Test Setup Block Diagram

For AC Mains or DC Ports:



For Signal or Telecommunication Ports:



9.3 Test Performance

Performance Criterion:	Mode	Verdict
	TM1-TM3	B
Note: TM3 for TT,TR		

9.4 Environmental Conditions

Temperature:	25 °C
Relative Humidity:	50%
ATM Pressure:	1011 mbar

9.5 Electrical Fast Transients Test Data



Test Mode		TM1-TM3							
EN 61000-4-4 Test Line		Test Levels (kV)							
		+0.5	-0.5	+1.0	-1.0	+2.0	-2.0	+4.0	-4.0
AC Main Power port	L	A	A	A	A	/	/	/	/
	N	A	A	A	A	/	/	/	/
	PE	/	/	/	/	/	/	/	/
	L-N	A	A	A	A	/	/	/	/
	L-PE	/	/	/	/	/	/	/	/
	N-PE	/	/	/	/	/	/	/	/
	L-N-PE	/	/	/	/	/	/	/	/
Signal ports	/	/	/	/	/	/	/	/	/

Test Result: Pass

WALTEK




10. Surges

10.1 Test Procedure


Test is conducting under the description of EN 61000-4-5.

10.2 Test Setup Block Diagram

For AC Mains or DC Ports:



For Signal or Telecommunication Ports:



10.3 Test Performance

Performance Criterion:	Mode	Verdict
	TM1-TM3	
Note: TM3 for TT,TR		

10.4 Environmental Conditions

Temperature:	25°C
Relative Humidity:	50%
ATM Pressure:	1011 mbar

10.5 Surge Test Data



Test Mode	TM1-TM3			
Voltage	Poll	Path	Pass	Fail
0.5kV	±	L-N	A	/
1kV	±	L-N	A	/
2kV	±	L-N, L-PE, N-PE	/	/
4kV	±	L-N, L-PE, N-PE	/	/

Test Result: Pass

WALTEK




11. Radio Frequency, Common Mode (C/S)

11.1 Test Procedure


Test is conducting under the description of EN 61000-4-6.

11.2 Test Setup Block Diagram

For AC Mains or DC Input:



For Signal or Telecommunication Ports:



11.3 Test Performance

Performance Criterion:	Mode	Verdict
	TM1-TM3	A
Note: TM3 for CT,CR		

11.4 Environmental Conditions

Temperature:	25 °C
Relative Humidity:	50%
ATM Pressure:	1011 mbar

11.5 Continuous Conducted Disturbances Test Data

Sweep frequency range: 150kHz~80MHz

Frequency step: 1% of fundamental

Dwell time: 1 second



Test Mode		TM1-TM3		
Level	Voltage (V) (rms, unmodulated)	Modulation:	Pass	Fail
1	1	AM 80%, 1kHz sinewave	/	/
2	3	AM 80%, 1kHz sinewave	A	/
3	10	AM 80%, 1kHz sinewave	/	/
X	Special	/	/	/

Test Result: Pass

WALTEK




12. Voltage Dips and Interruptions

12.1 Test Procedure

Test is conducting under the description of EN 61000-4-11.

12.2 Test Setup Block Diagram



12.3 Test Performance

Performance Criterion:	Mode	Verdict
	TM1-TM3	B for voltage dip/ C for voltage interruption
Note: TM3 for TT,TR		

12.4 Environmental Conditions

Temperature:	25 °C
Relative Humidity:	50%
ATM Pressure:	1011 mbar

12.5 Voltage Dips And Interruptions Test Data

U: Voltage dips in % U_T (U_T is rated voltage for the EUT)

T: Test duration

Level	U	T	Phase Angle	N	Pass	Fail
1	100%	10ms	0/90/180/270	3	A	/
2	100%	20ms	0/90/180/270	3	B	/
3	30%	500ms	0/90/180/270	3	B	/
4	100%	5000ms	0/90/180/270	3	B	/

Test Result: Pass



EXHIBIT 1 - EUT PHOTOGRAPHS

Please refer to “ANNEX”.

WALTEK



EXHIBIT 2 - TEST SETUP PHOTOGRAPHS

**Conducted Emission
Test Setup**




**Radiation Emission
Test View(30MHz to
1GHz)**





Harmonic/Flicker Test
View




EN 61000-4-2 Test View






EN 61000-4-3 Test View




EN 61000-4-4/5/11 Test
View





EN 61000-4-6 Test View



***** END OF REPORT *****

WALTEK



中国认可
国际互认
检测
TESTING
CNAS L4062



TEST REPORT

Reference No. : WTF22X09190623W005
Manufacturer..... : Mid Ocean Brands B.V.
Address : 7/F., Kings Tower, 111 King Lam Street, Cheung Sha Wan, Kowloon,
Hong Kong
Factory : 117237
Product Name : Table Light wireless charger
Model No. : MO6346
Standards : EN IEC 55015:2019
EN 61547:2009
EN IEC 61000-3-2:2019
EN 61000-3-3:2013+A1:2019
Date of Receipt sample : 2022-9-30
Date of Test..... : 2022-9-30 to 2022-12-06
Date of Issue : 2022-12-06
Test Report Form No. : WTX_EN IEC 55015_2019_B
Test Result..... : Pass

Remarks:

The results shown in this test report refer only to the sample(s) tested, this test report cannot be reproduced, except in full, without prior written permission of the company. The report would be invalid without specific stamp of test institute and the signatures of approver.

Prepared By:

Waltek Testing Group (Shenzhen) Co., Ltd.

Address: 1/F., Room 101, Building 1, Hongwei Industrial Park, Liuxian 2nd Road,
Block 70 Bao'an District, Shenzhen, Guangdong, China

Tel.: +86-755-33663308 Fax.: +86-755-33663309 Email: sem@waltek.com.cn

Tested by:

Dashan Chen

Dashan Chen

Approved by:

Silin Chen

Silin Chen



TABLE OF CONTENTS

1. GENERAL INFORMATION	5
1.1 PRODUCT DESCRIPTION FOR EQUIPMENT UNDER TEST (EUT)	5
1.2 TEST STANDARDS.....	6
1.3 TEST METHODOLOGY	6
1.4 EUT SETUP AND OPERATION MODE	7
1.5 PERFORMANCE CRITERIA FOR EMS.....	8
1.6 TEST EQUIPMENT LIST AND DETAILS	9
2. SUMMARY OF TEST RESULTS.....	11
3. CONDUCTED EMISSION.....	12
3.1 MEASUREMENT UNCERTAINTY	12
3.2 BASIC TEST SETUP BLOCK DIAGRAM	12
3.3 ENVIRONMENTAL CONDITIONS	12
3.4 SUMMARY OF TEST RESULTS.....	12
4. RADIATED ELECTROMAGNETIC DISTURBANCES (9KHZ TO 30MHZ)	15
4.1 MEASUREMENT UNCERTAINTY	15
4.2 BASIC TEST SETUP BLOCK DIAGRAM	15
4.3 ENVIRONMENTAL CONDITIONS	15
4.4 SUMMARY OF TEST RESULTS.....	15
5. RADIATED ELECTROMAGNETIC DISTURBANCES (30MHZ TO 1000MHZ)	19
5.1 MEASUREMENT UNCERTAINTY	19
5.2 BASIC TEST SETUP BLOCK DIAGRAM	19
5.3 CORRECTED AMPLITUDE & MARGIN CALCULATION.....	20
5.4 ENVIRONMENTAL CONDITIONS	20
5.5 SUMMARY OF TEST RESULTS.....	20
6. HARMONIC CURRENT EMISSIONS	23
6.1 TEST PROCEDURE	23
6.2 TEST STANDARDS	23
6.3 ENVIRONMENTAL CONDITIONS	23
6.4 BASIC TEST SETUP BLOCK DIAGRAM	23
6.5 HARMONIC CURRENT EMISSIONS TEST DATA.....	23
7. VOLTAGE FLUCTUATION FLICKER.....	24
7.1 TEST PROCEDURE	24
7.2 TEST STANDARDS	24
7.3 ENVIRONMENTAL CONDITIONS	24
7.4 BASIC TEST SETUP BLOCK DIAGRAM	24
7.5 VOLTAGE FLUCTUATION AND FLICKER TEST DATA.....	24
8. ELECTROSTATIC DISCHARGES (ESD).....	26
8.1 TEST PROCEDURE	26
8.2 TEST PERFORMANCE.....	26
8.3 ENVIRONMENTAL CONDITIONS	26
8.4 BASIC TEST SETUP BLOCK DIAGRAM	26
8.5 ELECTROSTATIC DISCHARGE IMMUNITY TEST DATA	27
9. CONTINUOUS RF ELECTROMAGNETIC FIELD DISTURBANCES (RS).....	28
9.1 TEST PROCEDURE	28
9.2 TEST PERFORMANCE.....	28
9.3 ENVIRONMENTAL CONDITIONS	28
9.4 BASIC TEST SETUP BLOCK DIAGRAM	28
9.5 CONTINUOUS RADIATED DISTURBANCES TEST DATA.....	29
10. ELECTRICAL FAST TRANSIENTS (EFT)	30
10.1 TEST PROCEDURE	30
10.2 TEST PERFORMANCE	30



Reference No.: WTF22X09190623W005

10.3 ENVIRONMENTAL CONDITIONS	30
10.4 BASIC TEST SETUP BLOCK DIAGRAM	30
10.5 ELECTRICAL FAST TRANSIENTS TEST DATA.....	31
11. SURGES.....	32
11.1 TEST PROCEDURE	32
11.2 TEST PERFORMANCE.....	32
11.3 ENVIRONMENTAL CONDITIONS	32
11.4 BASIC TEST SETUP BLOCK DIAGRAM.....	32
11.5 SURGE TEST DATA.....	32
12. CONTINUOUS INDUCED RF DISTURBANCES (C/S)	33
12.1 TEST PROCEDURE	33
12.2 TEST PERFORMANCE	33
12.3 ENVIRONMENTAL CONDITIONS	33
12.4 BASIC TEST SETUP BLOCK DIAGRAM	33
12.5 CONTINUOUS CONDUCTED DISTURBANCES TEST DATA	34
13. POWER-FREQUENCY MAGNETIC FIELDS (PFMF)	35
13.1 TEST PROCEDURE	35
13.2 TEST PERFORMANCE	35
13.3 ENVIRONMENTAL CONDITIONS	35
13.4 BASIC TEST SETUP BLOCK DIAGRAM	35
13.5 POWER-FREQUENCY MAGNETIC FIELD TEST DATA	35
14. VOLTAGE DIPS AND INTERRUPTIONS.....	36
14.1 TEST PROCEDURE	36
14.2 TEST PERFORMANCE	36
14.3 ENVIRONMENTAL CONDITIONS	36
14.4 BASIC TEST SETUP BLOCK DIAGRAM	36
14.5 VOLTAGE DIPS AND INTERRUPTIONS TEST DATA	36
EXHIBIT 1 - PRODUCT LABELING.....	错误!未定义书签。
PROPOSED CE LABEL FORMAT	错误!未定义书签。
PROPOSED LABEL LOCATION ON EUT	错误!未定义书签。
EXHIBIT 2 - EUT PHOTOGRAPHS	37
EXHIBIT 3 - TEST SETUP PHOTOGRAPHS.....	38

**Report version**

Version No.	Date of issue	Description
Rev.00	2022-12-06	Original
/	/	/

WALTEK



1. GENERAL INFORMATION

1.1 Product Description for Equipment Under Test (EUT)

General Description of EUT	
Product Name:	Table Light wireless charger
Trade Name:	/
Model No.:	MO6346
Adding Model(s):	/
<i>Note: The test data is gathered from a production sample, provided by the manufacturer.</i>	

Technical Characteristics of EUT	
Rated Voltage:	AC 230V 50Hz
Rated Current:	/
Rate Power:	Input: 5V/2A, 9V/2A Wireless Output: 10W Max
Power Adaptor Model:	/
Highest Internal Frequency:	Below 108MHz



1.2 Test Standards

The tests were performed according to following standards:

EN IEC 55015:2019:Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment.

EN 61547:2009:Electromagnetic for general lighting purposes - EMC immunity requirements.

EN IEC 61000-3-2:2019: Electromagnetic compatibility (EMC) -- Part 3-2: Limits - Limits for harmonic current emissions (equipment input current up to and including 16 A per phase).

EN 61000-3-3:2013+A1:2019: Electromagnetic compatibility (EMC) -- Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection.

Maintenance of compliance is the responsibility of the manufacturer. Any modification of the product maybe which result in lowering the emission/immunity should be checked to ensure compliance has been maintained.

1.3 Test Methodology

All measurements contained in this report were conducted with the standards EN IEC 55015 , EN IEC 61000-3-2, EN 61000-3-3 and EN 61547 for general lighting purposes equipment, and all related testing and measurement techniques intentional standards.



1.4 EUT Setup and Operation Mode

The equipment under test (EUT) was configured to measure its highest possible emission/immunity level. The test modes were adapted according to the operation manual for use, more detailed description as follows:

Test Mode List			
Test Mode	Description	Remark	Power Supply Mode
TM1	Normal Working	Lighting	AC230V/50Hz for adapter

EUT Cable List and Details				
Cable Description	Length (m)	Shielded/Unshielded	With / Without Ferrite	With / Without Chip
USB Cable	1.0	Unshielded	Without Ferrite	/

Special Cable List and Details				
Cable Description	Length (m)	Shielded/Unshielded	With / Without Ferrite	With / Without Chip
/	/	/	/	/

Auxiliary Equipment List and Details			
Description	Manufacturer	Model	Serial Number
wireless charging tester	YBZ	YBZ wireless charging tester	/
Adapter	Xiaomi	MDY-08-ES	/



1.5 Performance Criteria for EMS

All the test data has been collected, reduced, and analyzed within this report in accordance with Immunity requires the following as specific performance criteria:

- A. The apparatus shall continue to operate as intended during and after the test. The manufacturer specifies some minimum performance level. The performance level may be specified by the manufacturer as a permissible loss of performance.
- B. The apparatus shall continue to operate as intended after the test. This indicates that the EUT does not need to function at normal performance levels during the test, but must recover. Again some minimal performance is defined by the manufacturer. No change in operating state or loss of data is permitted.
- C. Temporary loss of function is allowed. Operation of the EUT may stop as long as it is either automatically reset or can be manually restored by operation of the controls.

WALTEK



1.6 Test Equipment List and Details

Description	Manufacturer	Model	Serial No.	Cal. Date	Due. Date
☐ Chamber A: Below 1GHz					
Spectrum Analyzer	Rohde & Schwarz	FSP30	836079/035	2022-03-22	2023-03-21
EMI Test Receiver	Rohde & Schwarz	ESVB	825471/005	2022-03-22	2023-03-21
Trilog Broadband Antenna	Schwarz beck	VULB9163	9163-333	2021-03-20	2023-03-19
Loop Antenna	Schwarz beck	FMZB 1516	9773	2021-03-20	2023-03-19
Amplifier	HP	8447F	2805A03475	2022-01-07	2023-01-06
☐ Chamber A: Above 1GHz					
Amplifier	C&D	PAP-1G18	2002	2022-03-22	2023-03-21
Horn Antenna	ETS	3117	00086197	2021-03-19	2023-03-18
☒ Chamber B: Below 1GHz					
Trilog Broadband Antenna	Schwarz beck	VULB9163(B)	9163-635	2021-04-09	2023-04-08
Amplifier	Agilent	8447D	2944A10179	2022-03-22	2023-03-21
EMI Test Receiver	Rohde & Schwarz	ESPI	101391	2022-03-25	2023-03-24
☐ Chamber C: Below 1GHz					
EMI Test Receiver	Rohde & Schwarz	ESIB 26	100401	2022-01-07	2023-01-06
Trilog Broadband Antenna	Schwarz beck	VULB 9168	1194	2021-05-28	2023-05-27
Amplifier	HP	8447F	2944A03869	2022-03-22	2023-03-21
☐ Chamber C: Above 1GHz					
Horn Antenna	POAM	RTF-11A	LP228060221	2022-06-16	2024-06-14
Amplifier	Tonscend	TAP01018050	AP22E806235	2022-06-17	2023-06-16
☒ Conducted Room 1#					
EMI Test Receiver	Rohde & Schwarz	ESPI	101611	2022-03-22	2023-03-21
Pulse Limiter	Rohde & Schwarz	ESH3-Z2	100911	2022-03-25	2023-03-24
AC LISN	Schwarz beck	NSLK8126	8126-224	2022-03-22	2023-03-21
8-WIRE LISN	Schwarz beck	8158	CAT3-8158-0059	2022-03-22	2023-03-21
8-WIRE LISN	Schwarz beck	8158	CAT5-8158-0117	2022-03-22	2023-03-21
☐ Conducted Room 2#					
EMI Test Receiver	Rohde & Schwarz	ESPI	10129	2022-03-22	2023-03-21
LISN	Rohde & Schwarz	ENV 216	100097	2022-03-22	2023-03-21
☒ Radiated Electromagnetic Disturbances (9KHz-30MHz)					
Loop Antenna	ZHINAN	ZN30401	19037	2021-04-26	2023-04-25
EMI Test Receiver	Rohde & Schwarz	ESPI	101611	2022-03-22	2023-03-21
☐ Harmonics & Flicker					
Digital Power Analyzer	California Instrument	CTS	72831	2022-03-22	2023-03-21



Power Source	California Instrument	5001IX-CTS-400	25965	2022-03-22	2023-03-21
☒ Electrostatic discharges					
ESD Generator	LIONCEL	ESD-203B	0170901	2022-03-28	2023-03-27
☒ Power-frequency magnetic field (PFMF)					
PMF Generator	LIONCEL	PMF-801C-C	0171101	2022-03-22	2023-03-21
PMF Antenna	LIONCEL	PMF-801C-A	0180302	2022-03-22	2023-03-21
Instantaneous PMF Generator Module	LIONCEL	PMF-801C-T	0171001	2022-03-22	2023-03-21
☒ Electronic fast transient(EFT)/Surges/Dips					
Transient 2000	EMC PARTNER	TRA2000	863	2022-03-22	2023-03-21
Couple Clamp	EMC PARTNER	CN-EFT1000	513	2022-03-22	2023-03-21
☒ Radio frequency, continuous conducted (C/S)					
CONDUCTED IMMUNITY TEST SYSTEM	FRANKONIA	CIT-10/75	126B1247/2013	2022-01-07	2023-01-06
Attenuator	EMTEST	MA-5100/6BF2	1009	2022-03-22	2023-03-21
CDN	Luthi	L-801M2/M3	2665	2022-03-22	2023-03-21
CDN	LIONCEL	CDN-T8	0210401	2022-03-25	2023-03-24
EM Clamp	TESEQ	KEMZ801A	45028	2022-03-25	2023-03-24
☒ Radio frequency electromagnetic Field (R/S)					
Signal Generator	HP	8688B	3438A00604	2022-03-22	2023-03-21
Power Sensor	Agilent	E9301A	MY52450001	2022-03-25	2023-03-24
Power Sensor	Agilent	E9304A	MY55081055	2022-03-25	2023-03-24
RF Power Amplifier	MicoTop	MPA-80-1000-250	MPA1906239	2022-03-22	2023-03-21
RF Power Amplifier	MicoTop	MPA-1000-6000-100	MPA1906238	2022-03-22	2023-03-21
Antenna	SCHWARZBECK	STLP 9129	9129 114	N/A	N/A
Power Meter	Agilent	E4419B	GB42420578	2022-03-22	2023-03-21



2. SUMMARY OF TEST RESULTS

Standards	Description of Test Item	Result
EN IEC55015	Disturbance Voltages	Compliant
	Radiated Electromagnetic Disturbances (Frequency range 9kHz to 30MHz)	Compliant
	Radiated Electromagnetic Disturbances (Frequency range 30MHz to 1000MHz)	Compliant
EN IEC 61000-3-2	Harmonic Current Emission	Compliant
EN 61000-3-3	Voltage Fluctuation And Flicker	Compliant
EN 61547	Electrostatic Discharge Immunity in accordance with EN 61000-4-2	Compliant
	Radio-Frequency Electromagnetic Field Immunity in accordance with EN 61000-4-3	Compliant
	Electrical Fast Transient/Burst Immunity in accordance with EN 61000-4-4	Compliant
	Surges Immunity in accordance with EN 61000-4-5	Compliant
	Injected Currents Immunity in accordance with EN 61000-4-6	Compliant
	Power-frequency Magnetic Field Immunity in accordance with EN 61000-4-8	Compliant
	Voltage Dips/Interruptions Immunity in accordance with EN 61000-4-11	Compliant

N/A: not applicable



3. Conducted Emission


3.1 Measurement Uncertainty

Base on NIS 81, The Treatment of Uncertainty in EMC Measurements, the best estimate of the uncertainty of any conducted emissions measurement:

Measurement uncertainty		
Parameter	Conditions	Uncertainty
Conducted Emissions	Conducted	9-150kHz $\pm 3.74\text{dB}$
		0.15-30MHz $\pm 3.34\text{dB}$

3.2 Basic Test Setup Block Diagram

AC port



3.3 Environmental Conditions


Temperature:	23.5 ° C
Relative Humidity:	54 %
ATM Pressure:	1015 mbar

3.4 Summary of Test Results

Please find the results below:




Test mode:	TM1	Polarity:	Line
------------	-----	-----------	------



No.	Frequency (MHz)	Reading (dBuV)	Correct (dB)	Result (dBuV)	Limit (dBuV)	Margin (dB)	Detector
1	0.5620	34.70	10.21	44.91	56.00	-11.09	QP
2	0.6180	39.74	10.20	49.94	56.00	-6.06	QP
3	0.6180	26.08	10.20	36.28	46.00	-9.72	AVG
4	0.6780	37.77	10.20	47.97	56.00	-8.03	QP
5	1.2780	22.88	10.17	33.05	46.00	-12.95	AVG
6	2.5580	33.44	10.26	43.70	56.00	-12.30	QP
7	2.5580	26.91	10.26	37.17	46.00	-8.83	AVG
8	2.9540	28.46	10.28	38.74	46.00	-7.26	AVG
9*	3.6740	30.88	10.29	41.17	46.00	-4.83	AVG
10	4.4740	35.64	10.32	45.96	56.00	-10.04	QP
11	5.1100	35.77	10.33	46.10	60.00	-13.90	QP
12	5.1100	32.81	10.33	43.14	50.00	-6.86	AVG



Test mode:	TM1	Polarity:	Neutral
------------	-----	-----------	---------



No.	Frequency (MHz)	Reading (dBuV)	Correct (dB)	Result (dBuV)	Limit (dBuV)	Margin (dB)	Detector
1	0.5580	34.28	10.21	44.49	56.00	-11.51	QP
2	0.6180	37.87	10.20	48.07	56.00	-7.93	QP
3	0.6180	24.93	10.20	35.13	46.00	-10.87	AVG
4*	0.6780	38.87	10.20	49.07	56.00	-6.93	QP
5	0.6780	25.43	10.20	35.63	46.00	-10.37	AVG
6	2.1540	24.72	10.25	34.97	46.00	-11.03	AVG
7	2.7940	33.07	10.27	43.34	56.00	-12.66	QP
8	2.9539	27.94	10.28	38.22	46.00	-7.78	AVG
9	3.7500	34.17	10.30	44.47	56.00	-11.53	QP
10	5.1060	35.30	10.33	45.63	60.00	-14.37	QP
11	5.1060	32.28	10.33	42.61	50.00	-7.39	AVG
12	5.5860	32.11	10.33	42.44	50.00	-7.56	AVG



4. Radiated Electromagnetic Disturbances (9kHz to 30MHz)


4.1 Measurement Uncertainty

Base on NIS 81, The Treatment of Uncertainty in EMC Measurements, the best estimate of the uncertainty of any radiation emissions measurement is ± 3.6 dB.

4.2 Basic Test Setup Block Diagram

The Radiation Electromagnetic Disturbance (9kHz to 30MHz) test was performed in accordance with the EN IEC 55015

2m Loop Antenna



4.3 Environmental Conditions


Temperature:	23.5 °C
Relative Humidity:	54 %
ATM Pressure:	1015 mbar

4.4 Summary of Test Results

Please find the results below:




Test mode:	TM1	Polarity:	X
------------	-----	-----------	---



No.	Frequency (MHz)	Reading (dBuA)	Correct (dB)	Result (dBuA)	Limit (dBuA)	Margin (dB)	Detector
1	0.1215	45.83	0.76	46.59	66.29	-19.70	QP
2	0.2460	32.25	0.76	33.01	52.06	-19.05	QP
3	0.3660	28.83	0.76	29.59	47.28	-17.69	QP
4*	1.4540	19.79	0.76	20.55	30.70	-10.15	QP
5	11.9300	9.31	0.77	10.08	22.00	-11.92	QP
6	19.7460	9.13	0.81	9.94	22.00	-12.06	QP




Test mode:	TM1	Polarity:	Y
------------	-----	-----------	---



No.	Frequency (MHz)	Reading (dBuA)	Correct (dB)	Result (dBuA)	Limit (dBuA)	Margin (dB)	Detector
1	0.1225	40.93	0.76	41.69	65.97	-24.28	QP
2	0.2540	24.13	0.76	24.89	51.67	-26.78	QP
3	0.3660	22.69	0.76	23.45	47.28	-23.83	QP
4	1.2100	19.89	0.76	20.65	32.91	-12.26	QP
5*	2.6420	12.80	0.76	13.56	23.53	-9.97	QP
6	14.6740	9.39	0.79	10.18	22.00	-11.82	QP



Test mode:	TM1	Polarity:	Z
------------	-----	-----------	---



No.	Frequency (MHz)	Reading (dBuA)	Correct (dB)	Result (dBuA)	Limit (dBuA)	Margin (dB)	Detector
1	0.1224	30.94	0.76	31.70	66.00	-34.30	QP
2	0.3660	22.61	0.76	23.37	47.28	-23.91	QP
3	1.0660	19.53	0.76	20.29	34.43	-14.14	QP
4*	2.7420	11.22	0.76	11.98	23.08	-11.10	QP
5	10.4100	8.68	0.76	9.44	22.00	-12.56	QP
6	28.3940	9.02	0.86	9.88	22.00	-12.12	QP




5. Radiated Electromagnetic Disturbances (30MHz to 1000MHz)

5.1 Measurement Uncertainty

Base on NIS 81, The Treatment of Uncertainty in EMC Measurements, the best estimate of the uncertainty of any radiation emissions measurement:

Measurement uncertainty		
Parameter	Conditions	Uncertainty
Radiated Emissions	Radiated	30-200MHz $\pm 4.52\text{dB}$
		0.2-1GHz $\pm 5.56\text{dB}$
		1-6GHz $\pm 3.84\text{dB}$
		6-18GHz $\pm 3.92\text{dB}$

5.2 Basic Test Setup Block Diagram





5.3 Corrected Amplitude & Margin Calculation

The Corrected Amplitude is calculated by adding the Antenna Factor and the Cable Factor, and subtracting the Amplifier Gain from the Amplitude reading. The basic equation is as follows:

$$\begin{aligned}\text{Corr. Ampl.} &= \text{Indicated Reading} + \text{Correct} \\ \text{Correct} &= \text{Ant. Factor} + \text{Cable Loss} - \text{Ampl. Gain}\end{aligned}$$

The “**Margin**” column of the following data tables indicates the degree of compliance with the applicable limit. For example, a margin of -6dB μ V means the emission is 6dB μ V below the maximum limit for a lighting device. The equation for margin calculation is as follows:

$$\text{Margin} = \text{Corr. Ampl.} - \text{EN IEC 55015 Limit}$$

5.4 Environmental Conditions

Temperature:	23.5 ° C
Relative Humidity:	54 %
ATM Pressure:	1011 mbar


5.5 Summary of Test Results

Please find the results below:

WALTEK




Test mode:	TM1	Polarity:	Horizontal
------------	-----	-----------	------------



No.	Frequency (MHz)	Reading (dBuV/m)	Correct dB/m	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Degree ()	Height (cm)	Remark
1	112.1305	38.57	-8.29	30.28	40.00	-9.72	-	-	QP
2	119.8556	39.23	-8.81	30.42	40.00	-9.58	-	-	QP
3	197.8928	35.06	-8.50	26.56	40.00	-13.44	-	-	QP
4	236.6447	31.15	-7.17	23.98	47.00	-23.02	-	-	QP
5	390.7226	34.88	-3.47	31.41	47.00	-15.59	-	-	QP
6	622.8900	28.11	0.18	28.29	47.00	-18.71	-	-	QP



Test mode:	TM1	Polarity:	Vertical
------------	-----	-----------	----------



No.	Frequency (MHz)	Reading (dBuV/m)	Correct dB/m	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Degree ()	Height (cm)	Remark
1	53.5052	42.67	-7.93	34.74	40.00	-5.26	-	-	QP
2	66.7325	46.11	-10.42	35.69	40.00	-4.31	-	-	QP
3	119.8556	41.64	-8.81	32.83	40.00	-7.17	-	-	QP
4	128.1130	42.32	-10.27	32.05	40.00	-7.95	-	-	QP
5	179.3863	45.77	-10.16	35.61	40.00	-4.39	-	-	QP
6	381.2487	30.35	-3.63	26.72	47.00	-20.28	-	-	QP

Remark: '-' Means' the test Degree and Height are not recorded by the test software and only show the worst case in the test report.



6. Harmonic Current Emissions

6.1 Test Procedure

Test is conducted under the description of EN IEC 61000-3-2.


6.2 Test Standards

EN IEC 61000-3-2, Clause 7.4 Limits for Class C equipment.

6.3 Environmental Conditions

Temperature:	24 °C
Relative Humidity:	51 %
ATM Pressure:	1022 mbar

6.4 Basic Test Setup Block Diagram



6.5 Harmonic Current Emissions Test Data

According to Clause 7.1 of EN IEC 61000-3-2, the rated power of the EUT (lighting equipment) is less than 5W, belong to 'equipment with a rated power of 5W or less', therefore 'limits are not specified in this edition of the standards'. It is deemed to fully fit the requirements of the standards.

Result: The EUT is compliance with the requirements of this section.

7.1 Test Procedure

7.2 Test Standards

7.3 Environmental Conditions

Temperature:	24 °C
Relative Humidity:	51 %
ATM Pressure:	1022 mbar

The diagram illustrates a laboratory setup for testing an Equipment Under Test (EUT). The EUT is placed on a stand that is 0.8m high. The stand is connected to the AC Mains. A Power Analyzer and an AC Source are also connected to the AC Mains. The Power Analyzer and AC Source are stacked on a stand that is also 0.8m high. The ground symbol is shown at the bottom right of the diagram.

Page 24 of 42




Test mode:	TM1
------------	-----

Test Result: Pass


Status: Test Completed

Pst_i and limit line

European Limits



Plt and limit line



Parameter values recorded during the test:

Vrms at the end of test (Volt): 230.07

Highest dt (%):

T-max (mS): 0

Highest dc (%): 0.00

Highest dmax (%): 0.00

Highest Pst (10 min. period): 0.224

Highest Plt (2 hr. period): 0.098

Test limit (%):

Test limit (mS): 500.0 Pass

Test limit (%): 3.30 Pass

Test limit (%): 4.00 Pass

Test limit: 1.000 Pass

Test limit: 0.650 Pass



8. Electrostatic Discharges (ESD)

8.1 Test Procedure

Test is conducted under the description of EN 61000-4-2.


8.2 Test Performance

Performance Criterion: B

8.3 Environmental Conditions

Temperature:	24 °C
Relative Humidity:	51 %
ATM Pressure:	1011 mbar

8.4 Basic Test Setup Block Diagram





8.5 Electrostatic Discharge Immunity Test Data

Test Mode: TM1

Table 1: Electrostatic Discharge Immunity (Air Discharge)

EN 61000-4-2 Test Points	Test Voltage (kV)									
	-2	+2	-4	+4	-6	+6	-8	+8	-15	+15
DC Charging port	A	A	A	A	A	A	A	A	/	/
Enclosure	A	A	A	A	A	A	A	A	/	/

Table 2: Electrostatic Discharge Immunity (Direct Contact)

EN 61000-4-2 Test Points	Test Voltage (kV)									
	-2	+2	-4	+4	-6	+6	-8	+8	-15	+15
Enclosure	A	A	A	A	/	/	/	/	/	/

Table 3: Electrostatic Discharge Immunity (Indirect Contact HCP & VCP)

EN 61000-4-2 Test Points	Test Voltage (kV)									
	-2	+2	-4	+4	-6	+6	-8	+8	-15	+15
HCP (6 Sides)	A	A	A	A	/	/	/	/	/	/
VCP (4 Sides)	A	A	A	A	/	/	/	/	/	/

Test Result: Pass



9. Continuous RF electromagnetic field Disturbances (RS)

9.1 Test Procedure

Test is conducted under the description of EN 61000-4-3.


9.2 Test Performance

Performance Criterion: A

9.3 Environmental Conditions

Temperature:	24 °C
Relative Humidity:	51 %
ATM Pressure:	1010 mbar

9.4 Basic Test Setup Block Diagram





9.5 Continuous Radiated Disturbances Test Data

Frequency step: 1% of fundamental
Dwell time: 1 second
Modulation: AM by 1kHz sine wave with 80% modulation depth
Test Mode: TM1

Frequency Range(MHz)	Field (V/m)	Front		Rear		Left Side		Right Side	
		VERT	HORI	VERT	HORI	VERT	HORI	VERT	HORI
80-1000	3	A	A	A	A	A	A	A	A

Test Result: Pass

WALTEK



10. Electrical Fast Transients (EFT)

10.1 Test Procedure

Test is conducted under the description of EN 61000-4-4.


10.2 Test Performance

Performance Criterion: B

10.3 Environmental Conditions

Temperature:	24 °C
Relative Humidity:	51 %
ATM Pressure:	1011 mbar

10.4 Basic Test Setup Block Diagram





10.5 Electrical Fast Transients Test Data

Test Mode: TM1

EN 61000-4-4 Test Points		Test Voltage (kV)							
		+0.5	-0.5	+1.0	-1.0	+2.0	-2.0	+4.0	-4.0
Power Supply Power Port of EUT	L	A	A	A	A	/	/	/	/
	N	A	A	A	A	/	/	/	/
	PE	/	/	/	/	/	/	/	/
	L+N	A	A	A	A	/	/	/	/
	L+PE	/	/	/	/	/	/	/	/
	N+PE	/	/	/	/	/	/	/	/
	L+N+PE	/	/	/	/	/	/	/	/
Signal ports	RJ45	/	/	/	/	/	/	/	/

Test Result: Pass

WALTEK



11. Surges

11.1 Test Procedure

Test is conducted under the description of EN 61000-4-5.


11.2 Test Performance

Performance Criterion: C

11.3 Environmental Conditions

Temperature:	24 °C
Relative Humidity:	51 %
ATM Pressure:	1011 mbar

11.4 Basic Test Setup Block Diagram



11.5 Surge Test Data

Test Mode: TM1

Test Voltage	Poll	Path	Pass	Fail
0.5kV	±	L-N	A	/
1kV	±	L-N	/	/
2kV	±	L-PE, N-PE	/	/
4kV	±	L-N, L-PE, N-PE	/	/

Test Result: Pass



12. Continuous Induced RF Disturbances (C/S)

12.1 Test Procedure

Test is conducted under the description of EN 61000-4-6.


12.2 Test Performance

Performance Criterion: A

12.3 Environmental Conditions

Temperature:	24 °C
Relative Humidity:	51 %
ATM Pressure:	1011 mbar

12.4 Basic Test Setup Block Diagram





12.5 Continuous Conducted Disturbances Test Data

Sweep frequency range: 0.15 MHz to 80 MHz
Frequency step: 1% of fundamental
Dwell time: 1 second
Test Mode: TM1
AC Port

Frequency MHz	Injected Position	Voltage level (e.m.f.)	Observations (Performance Criterion)	Result
0.15-80	AC Mains	1V	/	/
0.15-80	AC Mains	3V	A	Pass
0.15-80	AC Mains	10V	/	/

Test Result: Pass

WALTEK



13. Power-Frequency Magnetic Fields (PFMF)

13.1 Test Procedure

Test is conducted under the description of EN 61000-4-8.


13.2 Test Performance

Performance Criterion: A

13.3 Environmental Conditions

Temperature:	24 °C
Relative Humidity:	51 %
ATM Pressure:	1011 mbar

13.4 Basic Test Setup Block Diagram



13.5 Power-Frequency Magnetic Field Test Data

Test Mode: TM1

Level	Magnetic Field Strength (r.m.s) A/m	Frequency Hz	Induction Coil Position	Pass	Fail
1	1	50	X, Y, Z	/	/
2	3	50	X, Y, Z	A	/
3	10	50	X, Y, Z	/	/
X	Special	/	/	/	/

Test Result: Pass



14. Voltage Dips and Interruptions

14.1 Test Procedure

Test is conducted under the description of EN 61000-4-11.


14.2 Test Performance

Performance Criterion: B/C

14.3 Environmental Conditions

Temperature:	24 °C
Relative Humidity:	51 %
ATM Pressure:	1011 mbar

14.4 Basic Test Setup Block Diagram



14.5 Voltage Dips And Interruptions Test Data

Test Mode: TM1

U: Voltage dips in % U_T (U_T is rated voltage for the EUT)

T: Test duration

Level	U	T	Phase Angle	N	Pass	Fail
1	30%	200ms	0/90/180/270	3	B	/
2	100%	10ms	0/90/180/270	3	B	/

Test Result: Pass



EXHIBIT 1 - EUT PHOTOGRAPHS

Please refer to “ANNEX”.

WALTEK



EXHIBIT 2 - TEST SETUP PHOTOGRAPHS

**Conducted Emission
Test Setup**



**Radiation Emission
Test View
(9kHz~30MHz)**






**Radiation Emission
Test View(30MHz to
1GHz)**



**Harmonic/Flicker Test
View**






**EN 61000-4-2 Test
View**




**EN 61000-4-3 Test
View**






**EN 61000-4-4/5/11 Test
View**




**EN 61000-4-6 Test
View**





**EN 61000-4-8 Test
View**



***** END OF REPORT *****

WALTEK